



TORQUE AND LIMIT SWITCH OPERATION		
SWITCH	CLOSE ←	INTERMEDIATE → OPEN
CLS 1-2		
CLS 1-3		
OLS 1-2		
OLS 1-3		

SYMBOL	DESCRIPTION	RATING
CLS	CLOSE LIMIT SWITCH	250VAC 10A
OLS	OPEN LIMIT SWITCH	250VAC 10A
TP	THERMAL PROTECTOR	250VAC 15A

*EACH ACTUATOR SHOULD BE POWERED THROUGH IT'S OWN INDIVIDUAL SWITCH OR RELAY CONTACTS TO PREVENT CROSS FEED BETWEEN TWO OR MORE ACTUATORS.

PART NAME	1PH WIRING DIAGRAM STANDARD+PCU	
DWG. NO	HQ-1500-B	
DATE	31/10/2011	ISSUE REF: B
ACTUATED SOLUTIONS LTD	TEL: (01243) 827469	
HQ-008	FAX: (01243) 829418	
APPLICATION		