



TORQUE AND LIMIT SWITCH OPERATION

SWITCH	CLOSE ←	INTERMEDIATE	→ OPEN
CLS 1-2	█	█	█
CLS 1-3	█	█	█
OLS 1-2	█	█	█
OLS 1-3	█	█	█
ACLS 1-2	█	█	█
ACLS 1-3	█	█	█
AOLS 1-2	█	█	█
AOLS 1-3	█	█	█
CTS 1-3	* CLOSING TORQUE SWITCH INTERRUPTS CONTROL IF MECHANICAL OVERLOAD OCCURS DURING CLOSING CYCLE		
OTS 1-3	* OPENING TORQUE SWITCH INTERRUPTS CONTROL IF MECHANICAL OVERLOAD OCCURS DURING OPENING CYCLE		
SYMBOL	DESCRIPTION		RATING
CLS	CLOSE LIMIT SWITCH		250VAC 10A
OLS	OPEN LIMIT SWITCH		250VAC 10A
ACLS	AUX. CLOSE LIMIT SWITCH		250VAC 16A
AOLS	AUX. OPEN LIMIT SWITCH		250VAC 16A
CC	CLOSE MAGNETIC COIL		
OC	OPEN MAGNETIC COIL		
TP	THERMAL PROTECTOR		250VAC 15A

*EACH ACTUATOR SHOULD BE POWERED THROUGH IT'S OWN INDIVIDUAL SWITCH OR RELAY CONTACTS TO PREVENT CROSS FEED BETWEEN TWO OR MORE ACTUATORS.

3 PHASE WIRING DIAGRAM STANDARD

DWG. NO **HQ-3200-A**

DATE 1/4/2010 ISSUE REF: A

HQ-010
 HQ-008
 APPLICATION ACTUATED SOLUTIONS LTD
 TEL: (01243) 827469
 FAX: (01243) 829418