



TORQUE AND LIMIT SWITCH OPERATION

SWITCH	CLOSE ←	INTERMEDIATE	→ OPEN
CLS 1-2	█	█	█
CLS 1-3	█	█	█
OLS 1-2	█	█	█
OLS 1-3	█	█	█
ACLS1-2	█	█	█
ACLS1-3	█	█	█
AOLS1-2	█	█	█
AOLS1-3	█	█	█

CTS 1-3 * CLOSING TORQUE SWITCH INTERRUPTS CONTROL IF MECHANICAL OVERLOAD OCCURS DURING CLOSING CYCLE

OTS 1-3 * OPENING TORQUE SWITCH INTERRUPTS CONTROL IF MECHANICAL OVERLOAD OCCURS DURING OPENING CYCLE

SYMBOL	DESCRIPTION	RATING
CLS	CLOSE LIMIT SWITCH	250VAC 10A
OLS	OPEN LIMIT SWITCH	250VAC 10A
CTS	CLOSE TORQUE SWITCH	250VAC 10A
OTS	OPEN TORQUE SWITCH	250VAC 10A
ACLS	AUX. CLOSE LIMIT SWITCH	250VAC 16A
AOLS	AUX. OPEN LIMIT SWITCH	250VAC 16A
CC	CLOSE MAGNETIC COIL	
OC	OPEN MAGNETIC COIL	
TP	THERMAL PROTECTOR	250VAC 15A

*EACH ACTUATOR SHOULD BE POWERED THROUGH IT'S OWN INDIVIDUAL SWITCH OR RELAY CONTACTS TO PREVENT CROSS FEED BETWEEN TWO OR MORE ACTUATORS.

HQ-300	3 PHASE WIRING DIAGRAM STANDARD	
HQ-200		
HQ-120		
HQ-080		
HQ-060	DWG. NO	HQ-31000-A
HQ-050	DATE	10/5/2001
HQ-030	ISSUE REF:	A
HQ-020	ACTUATED SOLUTIONS LTD	
HQ-015	TEL: (01243) 827469	
APPLICATION	FAX: (01243) 829418	